

# 2018 Consumer Confidence Report

Water System Name: McCloud Community Services District

Report Date: 06/12/2019

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.*

**Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse [McCloud Comunista Cervices Distrito] a 220 test Minnesota avene, McCloud, Ca. 96057. Pone (530)964-2017 para asistirlo en español.**

Type of water source(s) in use: Spring Water

Name & general location of source(s): Intake Spring (Squaw Creek Spring) and the Elk Springs (Upper and Lower) which are all located north and north east of the town of McCloud.

Drinking Water Source Assessment information: Source water assessments were completed for all three springs in September 2002 by the State of California Department of Health Services. The vulnerability assessment identified that Illegal activities and unauthorized dumping as the most vulnerable activities. These activities were not associated with any detected contaminates. In November 2017, the State Water Resources Control Board had a representative complete a inspection of the McCloud Public water system. No serious Health Hazards were identified. These documents are available for viewing at the McCloud Community Services District office located at 220 West Minnesota Avenue McCloud Ca, 96057.

Time and place of regularly scheduled board meetings for public participation: The McCloud Community Services District's Board of directors Hold Regular board meetings the second and fourth Monday of each month at 6:00 in the evening located at Scout Hall, 405 E. Colombero Drive, McCloud Ca. Important Decisions regarding the operation, maintenance and replacement are made during these meetings. You are encouraged to attend and participate. Information is also available at our website: <https://ci.mccloudcsd.ca.us/>

For more information, contact: Kevin Dalton, General Manager

Phone: (530 ) 964-2017

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month) 2	1	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	0	Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste
(a) Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> .					

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER								
Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	8/31/16	10	0	0	15	0.2	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	8/31/16	10	0.579	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	5/22/18	4.2 mg/l	3.5 mg/l to 4.9 mg/l	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	5/22/18	11 mg/l	12.0 mg/l to 10 mg/l	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Radium 228 MDA95 pCi/L	8/15/15	0.31 pCi/L	0.30pCi/L to 0.32pCi/L	1.001 pCi/L	n/a	Erosion of natural deposits. Level detected is the average of both source samples results.
Perchlorate ug/l	5/22/18	<4.000 ug/l	n/a	6.000 Ug/l	4.000 ug/l	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts. Same level found in Intake Springs and the combined Elk Springs.
Gross ALFA pCi/L	8/15/15	0.420 pCi/L	0.355pCi/L to 0.485 pCi/L	15.000 pCi/L	n/a	Erosion of natural deposits. Level detected is the average of both source samples results.

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Specific Conductance uS/cm=	5/22/18	52 uS/cm	45 uS/cm to 59uS/cm	1600 uS/cm	0	Substances that form ions when in water; sea water influence.
Total Dissolved Solids mg/l	5/22/18	69 mg/l	63 mg/l to 74 mg/l	1000 mg/l	0	Runoff / leaching from natural deposits.

**TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
	N/A	N/A	N/A	N/A	N/A

### Other Samples Taken

Although the State requires that Public Water Suppliers test for Many potential contaminants it only requires that we include sample data that we detected in our water system. Some of the contaminants we test for that are of popular concern are **Nitrates, Nitrites Trihalomethanes, Arsenic and Lead**. The test results for these contaminants indicated **no detectable levels** in our water system.

The MCSD also tests for Alkalinity (total as CAC03) which had a result of 27 mg/l, magnesium had a result of 2 mg/l, calcium had a test result of 5 mg/l, there is no established state testing standard for these items. A pH of 6.9600 which is considered Neutral on the pH scale, these were tested on 05/22/2018. If you would like more information on testing for other potential contaminants not listed in this report, please contact Amos McAbier, Public Works Superintendent, at the McCloud Community Services District.

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The McCloud Community Services District is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

**OPTIONAL:** If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

### Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
<b>MCL (Maximum contaminate level) More than on positive bac-t sample in a month.</b>	The standard is that no more than one sample per month can be total coliform-positive and we had two samples that were total coliform-positive in one month.	From 09/19/18 to 09/22/18	Comply with state sampling procedures. Sampled several locations in the distribution system to determine if Coliforms were present.	Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

**MCL violation information**

For the month of September 2018, we took a total of 14 water samples. we had 2 water samples that tested present for coliforms- negative for E-coli and fecal coliforms.

We had 12 samples that were negative for any coliforms.

The McCloud Community Services District (MCSD) routinely monitors for the presence of drinking water contaminants by taking two routine total coliform bacteria samples per month. In September 2018, one of our samples was total coliform-positive. The District took seven follow-up samples the day after learning of the positive result and one of the seven follow-up samples came back total coliform-positive. The standard is that no more than one sample per month can be total coliform-positive and we had two samples that were total coliform- positive in one month. After receiving notification of the second positive sample, five additional confirmation samples were collected, all of which were negative for coliforms.

The number of coliforms found in the sample were very low- <2 MPN/100 ml.

The sampling conditions for these two samples were not the best, it was windy, Smokey and dusty.

It is possible that small particles carried by wind could have been the reason for coliforms present in the two samples. (possible sampling error)

We were required to retest several points in the system and all these confirmation/ repeat samples came back negative for any presence of coliforms. As of 22 September 2018, The problem has been resolved.

The State Water Resources Control Board, Division o(Drinking Water has issued a citation for this violation. The citation may be viewed at the following web address:

[http://www.waterboards.ca.gov/drinking\\_water/programs/EnforcementActionsSiskiyou.shtml](http://www.waterboards.ca.gov/drinking_water/programs/EnforcementActionsSiskiyou.shtml)

**For Water Systems Providing Groundwater as a Source of Drinking Water**

**TABLE 7 – SAMPLING RESULTS SHOWING  
FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLES**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	N/A	0	(0)	Human and animal fecal waste
Enterococci	0	N/A	TT	N/A	Human and animal fecal waste
Coliphage	0	N/A	TT	N/A	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Groundwater Source Samples,  
Uncorrected Significant Deficiencies, or Groundwater TT**

<b>SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUNDWATER SOURCE SAMPLE</b>
None
<b>SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES</b>
None

VIOLATION OF GROUNDWATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
None				
None				

**For Systems Providing Surface Water as a Source of Drinking Water**

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES	
Treatment Technique <sup>(a)</sup> (Type of approved filtration technology used)	N/A
Turbidity Performance Standards <sup>(b)</sup> (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to ____ NTU in 95% of measurements in a month. 2 – Not exceed ____ NTU for more than eight consecutive hours. 3 – Not exceed ____ NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	N/A
Highest single turbidity measurement during the year	N/A
Number of violations of any surface water treatment requirements	N/A

- (a) A required process intended to reduce the level of a contaminant in drinking water.
- (b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

**Summary Information for Violation of a Surface Water TT**

VIOLATION OF A SURFACE WATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
N/A				

**Summary Information for Operating Under a Variance or Exemption**

Not operating under an Exemption or Variance

---



---



---



---

## Summary Information for Federal Revised Total Coliform Rule Level 1 and Level 2 Assessment Requirements

### Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct **one** Level 1 assessment. **One** Level 1 assessment was completed. In addition, we were required to take **five** corrective actions and we completed **three** of these actions.

#### Level 1 assessment corrective actions-

Remove roots from inside upper elk vault- completed.

Flush dead-end water lines-completed/ongoing maintenance required.

Wasps in lower elk spring house- removed/ongoing maintenance. Wooden structure (Spring house) needs to be vaulted in concrete, ongoing maintenance plugging cracks in wooden structure, need a grant to accomplish vaulting- incomplete.

Test all backflow devices- incomplete.

Conduct sampling procedures in best conditions possible- ongoing awareness/ completed.

### Level 2 Assessment Requirement Due to an *E. coli* MCL Violation

*E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were **Not** required to complete a Level 2 assessment because we found **No** *E. coli* in our water system.